

Compound	Sample Point					
	Coles Run	Hershey Well	Ridgeview Well	Hurdis Well	Lyndhurst Well	
PFHxA	ND	ND	ND	ND	ND	
PFHpA	ND	ND	ND	ND	ND	
PFOA	ND	ND	ND	ND	ND	
PFNA	ND	ND	ND	ND	ND	
PFDA	ND	ND	ND	ND	ND	
PFUnA	ND	ND	ND	ND	ND	
PFDoA	ND	ND	ND	ND	ND	
PFTriA	ND	ND	ND	ND	ND	
PFTeA	ND	ND	ND	ND	ND	
PFBS	ND	ND	ND	ND	ND	
PFHxS	ND	ND	ND	ND	ND	
PFOS	ND	ND	ND	ND	ND	
NMeFOSAA	ND	ND	ND	ND	ND	
NEtFOSAA	ND	ND	ND	ND	ND	
F-53B Major	ND	ND	ND	ND	ND	
F-53B Minor	ND	ND	ND	ND	ND	
HFPO-DA (GenX)	ND	ND	ND	ND	ND	
DONA	ND	ND	ND	ND	ND	

Notes:

1. Analysis conducted by Eurofins TestAmerica, Sacramento
2. Samples were all "Finished Water" (after treatment)
3. Samples were analyzed July 9, 2020
4. ND denotes "Not Detected at the reporting limit"