	Sample Point						
Compound	Middlebrook	Deerfield	Augusta Springs	Churchville 3 & 5	Coles Run (1)	Coles Run (2)	Churchville 6
11CI-PF3OUdS	ND	ND	ND	ND	ND	ND	ND
4:2 FTS	ND	ND	ND	ND	ND	ND	ND
6:2 FTS	ND	ND	ND	ND	ND	ND	ND
8:2 FTS	ND	ND	ND	ND	ND	ND	ND
9CI-PF3ONS	ND	ND	ND	ND	ND	ND	ND
ADONA	ND	ND	ND	ND	ND	ND	ND
HFPO-DA (GenX)	ND	ND	ND	ND	ND	ND	ND
NFDHA	1.7 J	ND	ND	ND	ND	0.65 J	1.8 J
PFBS	ND	ND	ND	0.63 J	ND	ND	ND
PFDA	ND	ND	ND	ND	ND	ND	ND
PFHxA	ND	ND	ND	0.61 J	ND	ND	ND
PFBA	ND	ND	ND	ND	3.1 *	0.76 J	ND
PFEESA	ND	ND	ND	ND	ND	ND	ND
PFHpS	ND	ND	ND	ND	ND	ND	ND
PFMBA	ND	ND	ND	ND	ND	ND	ND
PFMPA	ND	ND	ND	ND	ND	ND	ND
PFPeA	ND	ND	ND	0.61 J	ND	ND	ND
PFPeS	ND	ND	ND	ND	ND	ND	ND
PFDoA	ND	ND	ND	ND	ND	ND	ND
PFHpA	ND	ND	ND	ND	ND	ND	ND
PFHxS	ND	ND	ND	ND	ND	ND	ND
PFNA	ND	ND	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	0.75 J	ND	ND	ND
PFOA	ND	ND	ND	0.57 J	ND	ND	ND
PFUnA	ND	ND	ND	ND	ND	ND	ND

## Notes:

- 1. Analysis conducted by Pace Analytical Ormond Beach
- 2. Samples were all "Finished Water" (after treatment)
- 3. Samples were analyzed December 7, 2022 thought December 10, 2022
- 4. "ND" denotes "Not Detected"
- 5. "J" denotes an estimated concentration below the reporting limit  $% \left( 1\right) =\left( 1\right) \left( 1\right)$
- 6. \* denotes reported value where an isotope failure was recorded in the sample and the quality control. The sample was tested a second time and results are shown in the Coles Run (2) column.