

ADDITIONAL and FOLLOW-UP RAW WATER SOURCE (WELL, SPRING or RESERVOIR)						
April 23, 2024 Sample Date			June 4, 2024 Sample Date			
Compound	Churchville No 3	Berry Farm Spring	Churchville No 6	Churchville No 3	Churchville No 5	Churchville No 6
Analyzed Using EPA Method 533						
PFBA	ND	ND	ND	ND	ND	ND
PFPeA	ND	ND	ND	ND	2.0	ND
PFHxA	ND	ND	ND	ND	2.0	ND
PFHpA	ND	ND	ND	ND	ND	ND
PFOA	ND	ND	ND	ND	2.1	ND
PFNA	ND	ND	ND	ND	ND	ND
PFDA	ND	ND	ND	ND	ND	ND
PFUnA	ND	ND	ND	ND	ND	ND
PFDoA	ND	ND	ND	ND	ND	ND
PFBS	ND	ND	ND	ND	1.9	ND
PFPeS	ND	ND	ND	ND	ND	ND
PFHxS	ND	ND	ND	ND	ND	ND
PFHpS	ND	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	ND	2.9	ND
PFEESA	ND	ND	ND	ND	ND	ND
4:2 FTS	ND	ND	ND	ND	ND	ND
6:2 FTS	ND	ND	ND	ND	ND	ND
8:2 FTS	ND	ND	ND	ND	ND	ND
HFPO-DA	ND	ND	ND	ND	ND	ND
ADONA	ND	ND	ND	ND	ND	ND
9Cl-PF3ONS	ND	ND	ND	ND	ND	ND
11Cl-PF3OUdS	ND	ND	ND	ND	ND	ND
PfMOBA	ND	ND	ND	ND	ND	ND
PfMPA	ND	ND	ND	ND	ND	ND
PfDHA	ND	ND	ND	ND	ND	ND
Analyzed Using EPA Method 537.1						
PFTeDA	ND	ND	ND	ND	ND	ND
PFTTrDA	ND	ND	ND	ND	ND	ND
NMeFOSAA	ND	ND	ND	ND	ND	ND
NEtFOSAA	ND	ND	ND	ND	ND	ND

Notes:

1. Analysis conducted by Eurofins Eaton Analytical South Bend
2. Samples were all "Raw Water" (before any treatment)
3. Both EPA Method 533 and EPA Method 537.1 were used in testing
4. First three samples were taken on April 23, 2024. Second series of samples were taken on June 4, 2024
5. All values are recorded in parts per trillion (also referred to as nanograms per liter)