

		RAW WATER SOURCE (WELL, SPRING or RESERVOIR)					
Compound		Middlebrook	Augusta Springs	Deerfield	Churchville No 3	Churchville No 5	Churchville No 6
Analyzed Using EPA Method 533							
PFBA		ND	ND	ND	ND	ND	ND
PFPeA		ND	ND	ND	ND	ND	ND
PFHxA		ND	ND	ND	ND	ND	ND
PFHpA		ND	ND	ND	ND	ND	ND
PFOA		ND	ND	ND	ND	1.9	ND
PFNA		ND	ND	ND	ND	ND	ND
PFDA		ND	ND	ND	ND	ND	ND
PFUnA		ND	ND	ND	ND	ND	ND
PFDoA		ND	ND	ND	ND	ND	ND
PFBS		ND	ND	ND	ND	2.4	ND
PFPeS		ND	ND	ND	ND	ND	ND
PFHxS		ND	ND	ND	ND	ND	ND
PFHpS		ND	ND	ND	ND	ND	ND
PFOS		ND	ND	ND	ND	3.5	ND
PFEESA		ND	ND	ND	ND	ND	ND
4:2 FTS		ND	ND	ND	ND	ND	ND
6:2 FTS		ND	ND	ND	ND	ND	ND
8:2 FTS		ND	ND	ND	ND	ND	ND
HFPO-DA		ND	ND	ND	ND	ND	ND
ADONA		ND	ND	ND	ND	ND	ND
9Cl-PF3ONS		ND	ND	ND	ND	ND	ND
11Cl-PF3OUdS		ND	ND	ND	ND	ND	ND
PFMOBA		ND	ND	ND	ND	ND	ND
PFMPA		ND	ND	ND	ND	ND	ND
PFDHA		ND	ND	ND	ND	ND	ND
Analyzed Using EPA Method 537.1							
PFTeDA		ND	ND	ND	ND	ND	ND
PFTTrDA		ND	ND	ND	ND	ND	ND
NMeFOSAA		ND	ND	ND	ND	ND	ND
NEtFOSAA		ND	ND	ND	ND	ND	ND

Notes:

1. Analysis conducted by Eurofins Eaton Analytical South Bend
2. Samples were all "Raw Water" (before any treatment)
3. Both EPA Method 533 and EPA Method 537.1 were used in testing
4. All samples were analyzed (both methods) on March 26, 2024
5. All values are recorded in parts per trillion (also referred to as nanograms per liter)