



18 Government Center Ln, PO Box 859, Verona, VA 24482

Phone: (540) 245-5681

augustawater.com

**Invitation to Bid (ITB) #2504
Ductile Pipe & Fittings – Hickory Hill
Addendum #2 and Acknowledgement**

To: Prospective Bidders
From: Jesse Roach, Augusta Water
Date: 12/5/24

As a reminder, all bids over \$500,000 must include a bid bond. Failure to include a bid bond will result in disqualification.

Augusta Water received the following question from a bidder. The answer is provided below.

1. Attachment A calls out 6", 8", 12", and 16" Mega Lugs. Does this just mean the gland or do we want the kits that include the gland, gasket, and bolts?
 - a. The mega lug line item for each size should include the gland, gasket, bolts, and nuts.

Please print all pages of this addendum and sign and date the acknowledgement below indicating that you have received the changes to the specifications and include it with your submittal for your bid to be considered.

I acknowledge receipt of this Document and the Addendum Changes:

Bidder's Signature

Date

Printed Name